Product Details Page 1 of 2

## Return to search

# **Print Page**



Product 21997

Number: Order

FO32/730/ECO

Abbreviation:

General
Description:

32W, 48" MOL, T8 OCTRON fluorescent lamp, 3000K color temperature, rare earth phosphor, 78 CRI, suitable for IS or RS

operation, ECOLOGIC

## **Product Information**

Abbrev. With Packaging Info. FO32730ECO 30/CS 1/SKU

Actual Length (in) 47.78
Actual Length (mm) 1213.6
Average Rated Life (hr) 25000

Base Medium Bipin

Bulb T8
Color Rendering Index (CRI) 78
Color Temperature/CCT (K) 3000
Diameter (in) 1.10
Diameter (mm) 27.9

Family Brand Name Octron® 700, Ecologic Industry Standards ANSI C78.81 - 2001

Initial Lumens at 25C 2800

Mean Lumens at 25C 2520

Nominal Length (in) 48

Nominal Wattage (W) 32.00

#### **Additional Product Information**

**Product Documents, Graphs, and Images** 

**Compatible Ballast** 

**Packaging Information** 



Product Details Page 2 of 2

#### **Footnotes**

- The life rating of FO32/700/ECO OCTRON® lamps operated on rapid start ballasts is 25,000 hours. The life rating of FO32/700/ECO OCTRON lamps operated on instant start ballasts is 24,000 hours.
- Approximate initial lumens after 100 hours operation.
- The life ratings of fluorescent lamps are based on 3 hr. burning cycles under specified conditions and with ballast meeting ANSI specifications. If burning cycle is increased, there will be a corresponding increase in the average hours life.
- Minimum starting temperature is a function of the ballast; consult the ballast manufacturer.
- OCTRON lamps should be operated only with magnetic rapid start ballasts designed to operate 265 mA, T-8 lamps or high frequency (electronic) ballasts that are either instant start, or rapid start, or programmed rapid start specifically designed to operate T8 lamps. OCTRON lamps may be operated on instant start ballasts with ballast factors ranging from a minimum of 0.71 to a maximum of 1.20 at the nominal ballast input voltage. When OCTRON lamps are operated in the instant start mode, the two wires or two contacts of each socket should be connected to each other. They should then be connected to the appropriate ballast lead wire using National Electric Code techniques.
- SYLVANIA ECOLOGIC fluorescent lamps are designed to pass the Federal Toxic Characteristic Leaching Procedure (TCLP) criteria for classification as non-hazardous waste in most states. TCLP test results are available upon request. Lamp disposal regulations may vary, check your local & state regulations. For more information, please visit www.lamprecycle.org

Print Page