



CONDITION OF ACCEPTABILITY FOR FHS2-UNV-36L

UL Condition of Acceptability - UL file # E313578, when installed in the end use equipment, the following are among the considerations to be made.

1. These products have been evaluated for use with an LED load as specified in the rating table: 3.2VDC, 0.70A. Use with any other load shall be evaluated in the end product.
2. The need for the minimum light output test shall be considered in the end product.
3. Battery compartment ventilation test was not considered on the product. Testing shall be considered when used in sealed or gasketed compartments in the end-use products.
4. The product has been evaluated for use in the damp locations. Suitability of the product for use in wet locations shall be determined in the end-use product.
5. The product was evaluated at a rated ambient temp of 50°C, additional evaluation shall be considered when used in an ambient other than as specified.
6. Grounding of the unit provided through metal mounting tabs of enclosure (no external supply ground conductor.)
7. The suitability of input, output and test switch leads shall be determined in the end use product.
8. Battery location, Battery enclosure and Battery mounting was not evaluated. Suitability of the Battery enclosure, Battery location and mounting means shall be determined in the end use product.
